



New Hampshire Fish and Game Department  
Powder Mill Fish Hatchery  
288 Merrymeeting Road  
New Durham, NH 03855  
Telephone: 603/859-2041

July 19, 2018

Norma Mason  
US Environmental Protection Agency  
Water Technical Unit - SEW  
PO Box 8127  
Boston, MA 02114-8127

**RE: Federal Permit Number: NH0000710  
Discharge 002**

Dear Ms. Mason:

Enclosed are the June 2014 Quarterly Discharge 002 Monitoring Reports for the Powder Mill Fish Hatchery. I entered a value of "0" for any of the parameters that were below the minimum detection levels. These minimum detection levels are as follows: <2mg/l for Suspended Solids, <1.0 mg/l for total Nitrogen, < 0.01mg/l for Phosphorous and <1.0mg/l for BOD.

Our quarterly water tests are performed by ChemServe in Milford, NH. The test methods for the parameters are as follows: Total Suspended Solids SM 2540D, BOD 5210B, Nitrogen In House, Nitrate EPA 300.0, Ammonia SM4500-NH3-C and Phosphorus EPA 200.7

---

Thomas W. Givetz

Thomas W. Givetz  
Superintendent  
Powder Mill Hatchery

